

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 1583

Dated: 12-06-2023

It is certified that an inspection team headed by
Blupinder Singh J.F. (Name of Officers with designation) from
PHED Department.

(Name of Department/ Office) inspected the Arbour Grove School, Pehowa- Cheeka Road,
Siana Saidan (Name & Address of the school) on 12/6/23 (Date of inspection) and
found that the Arbour Grove School, Pehowa (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

The above is valid for a period of 1/6/23 - 30/5/24

Signature with Seal:  Sub Divisional Engineer.
Name : Public Health Engineering Sub. Divn.
Designation: PEHOWA(KKR)
Name & Address of the Office / Department:
.....

To

Arbour Grove School
Pehowa-Cheeka Road, Siana Saidan, Pehowa
(Name & Address of the Institution)

Memo No:- 834

Date:- 12/06/2023

Subject : **Bacteriological Examination Report of Water Sample**

Sample Details		Date & Time
Sample ID: KKR/01066/6/2023	Sample Classification: Private	Collected By :8529037107
Sender: Arbour Grove School22046	Location :- , Saina Saidan Cheeka Road Pehowa	Collection Date :08/06/2023 at 12:31
Latitude :- 76.546980	Longitude :- 30.021757	Received at lab :08/06/2023 at 13:27
		Tested at Lab :12/06/2023

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



NISHA SAINI,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY,KURUKSHETRA
email:-chemist.kkra@phedharyana.gov.in

-----End of Report-----

Manager
Arbour Grove School
Saina Saidan,Pehowa