

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Memo No.: 721

Dated: 21/05/2026

It is certified that an inspection team headed by Bhupinder Singh, J.E. from PHED Department inspected the Arbour Grove School, Pehowa- Cheeka Road, Siana Saidan on 15/05/2026 and found that the Arbour Grove School, Pehowa has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

The above is valid for a period of 15/05/2026 – 14/05/2027

Signature with Seal.....
Name.....
Designation.....
Name & Address of the Office/Department.....

[Signature]
Sub Divisional Engineer
Public Health Engineering Sub.Divn.
PEHOWA(KKR)

To

Arbour Grove School
Pehowa- Cheeka Road, Siana Saidan, Pehowa



PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY ,KURUKSHETRA

Website :- <https://phedharyana.gov.in/>

Memo No:- 837

Date:- 15/05/2026

Subject : **Bacteriological Examination Report of Water Sample**

Sample ID: KKR/01144/5/2026		Sample Details	Date & Time
Sample Classification: Private		Collected By	RAJAT BANSAL,8529037107
Sender: ARBOUR GROVE SCHOOL		Collection Date	13/05/2026 at 11:34
Location :- , ARBOUR GROVE SCHOOL, SIANA SAIDAN, CHEEKA ROAD,		Received at lab	13/05/2026 at 15:54
Latitude :- 76.546178 Longitude :- 30.021357		Tested at Lab	15/05/2026

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"




NISHA SAINI, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY, KURUKSHETRA
email:-chemist.kkra@phedharyana.gov.in

-----End of Report-----.



Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory, Kurukshetra.
Jal Bhawan Sector-10 Kkr. Email id:-chemist.kkra@gmail.com.

Test Report

URL No. : TC4560250000262 F	Sample Collected on Date : 13/05/2026
Test Report No.: KKR/01143/5/2026	Sample Received on Date : 13/05/2026
Sender's Add : ARBOUR GROVE SCHOOL, SIANA SAIDAN, CHEEKA ROADKurukshetra.	Sample Location : ARBOUR GROVE SCHOOL, SIANA SAIDAN, CHEEKA ROADKurukshetra.
Customer Reference No. : 0	Sample Quantity : 1 Ltr.
Sample Description : Water	Date of Analysis Started : 13/05/2026
Sample Type : Physico-Chemical Analysis	Date of Analysis Completed : 15/05/2026
Memo No. : 838 Date: 15/05/2026	Date of issue : 15/05/2026

RESULTS						Unit
S.No.	Parameter	Protocol used	Result	IS:10500:2012(Second revision)		
				Acceptable Limit	Permissible limit in the absence of alternate source	
1	Colour	IS 3025Part-4: 2021	<05	5	15	Hazen
2	Odour	IS 3025Part-5: 2018	Agreeable	Agreeable	Agreeable	-
3	Taste	IS 3025Part-8: 2023	Agreeable	Agreeable	Agreeable	-
4	Total Dissolve Solids (180°C)	IS 3025Part-16: 2023	135	500	2000	mg/L
5	Total Hardness (as CaCo3)	IS 3025Part-21: 2009 RA 2023	100	200	600	mg/L
6	Calcium (as Ca)	IS 3025Part-40: 2024	170.34	75	200	mg/L
7	Magnesium (as Mg)	IS 3025Part-46: 2023	13.36	30	100	mg/L
8	Total Alkalinity (as CaCo3)	IS 3025Part-23: 2023	40.0	200	600	mg/L
9	Chloride (as Cl)	IS 3025Part-32: 1988 RA 2019	45.09	250	1000	mg/L
10	Sulphate (as So4)	IS 3025 Part-24 Sec.1 :2022	30.00	200	400	mg/L
11	Fluoride (as F)	IS 3025Part-60: 2023	0.64	1.0	1.5	mg/L
12	Iron (as Fe)	IS 3025 Part-53: 2024	0.05	1.0	No Relaxation	mg/L
13	Nitrate(as NO3)	APHA 4500-NO3B	BDL (DL=0.1)	45	No Relaxation	mg/L
14	pH (25°C)	IS 3025Part-11: RA 2022	7.36	6.5 to 8.5	No Relaxation	-
15	Turbidity	APHA2130 B 2023	BDL	1	5	NTU

Notes:

- 1 The Results given above are related to the sample as received and tested in PHED Lab, Kurukshetra.
- 2 Reliability of sample lies with the sender. Sample not collected by this Laboratory and sample is collected by sender himself.
- 3 The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- 4 The test report can't be used for any publicity or any legal purpose.
- 5 The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
- 6 Abbreviation used (mg/L = milligram per liter, BDL= Below Detection Limit, APHA= American Public Health Association, IS= Indian Standard, NA= Not Applicable, NTU= Nephelometric Turbidity unit, RA= Reaffirmed)
- 7 Test Performed at Temperature= 25 ± 5° C and Humidity Condition Limit: 50 ± 20%.

Reviewed By

(Nisha Saini)
Authorized Signatory/Chemist
PHED Water Testing Laboratory
Kurukshetra



End of the Report